



Rule 1109.1 – NO_x Emission Reduction for Refinery Equipment

Working Group Meeting #7
April 30, 2019

Agenda

2

- 
- Summary of Working Group Meeting #6
 - Progress of Rule Development
 - Third Party BARCT Review
 - Technology Manufacturer Meetings
 - Ammonia Slip and Particulate Matter
 - Cost Effectiveness
 - Next Steps

Progress of Rule Development

3

Summary of Working Group #6 (1/31/19)

- Presented revised analysis of heater and boiler data from survey
- Presented meetings with technology manufacturers
- Discussed burner control technology

Since Last Working Group Meeting

- Administrative Committee approved staff recommendation for BARCT Request For Proposal on 4/12/19
- Continued meetings with technology suppliers
- Site visit to asphalt refinery using ClearSign Duplex Plug & Play technology
- Western States Petroleum Association (WSPA) Meeting
 - Staff requested more information from stakeholders
- Marathon Petroleum Corporation stakeholder meeting & site visit
- Continuing site visits



Third Party BARCT Review

Third Party BARCT Review

5

- Recommended two technically qualified consultants:
 - Norton Engineering
 - Fossil Energy Research Corporation (FERCo)
- Each consultant will perform separate task
- Tasks proposed by staff:
 - Norton Engineering
 - Review staff's BARCT analysis
 - Research international low-NOx installations (achieved in practice)
 - Control technologies
 - Costs
 - FERCo
 - Difficult installations and/or retrofits
 - Space constraints
 - Burner technology installations
 - Selective catalytic reduction (SCR) and Ammonia injection grid (AIG) optimization
- Seeking approval at May Governing Board Meeting

Third Party BARCT Review (cont'd)

6

Norton Engineering	Fossil Energy Research Corporation (FERCo)
Extensive experience in refineries and petroleum process	Extensive background/experience in combustion and post combustion NOx control technology
Experienced in refinery NOx control projects	Comprehensive understanding and extensive experience with SCR systems
Experienced in refinery boiler and fired heater emission controls	Numerous technical presentations at technical conferences pertaining to NOx controls
Process design experience with NOx controls	Experienced in configuring process equipment with existing equipment
Experienced in refinery heater optimization	Extensive experience with ammonia injection systems and optimizations
Experienced in refinery FCC NOx controls	Experienced in refinery NOx emission systems and optimization
Performed previous 2015 BARCT RECLAIM assessment for SCAQMD	Numerous NOx technology assessment studies






Technology Manufacturer Meetings

Tri-Mer UltraCat Technology

8

- Met with Tri-Mer on 2/21/19 to discuss UltraCat multi-pollutant control technology
- Catalytic ceramic filter system can remove NO_x, SO_x, and PM
 - Nano-form of catalyst embedded inside ceramic filter walls
 - Extended catalyst life and performance when compared to SCR
 - Ceramic filters can achieve 10+ years of service
 - New ceramic filters allow for smaller footprint of equipment
 - NO_x removal not affected by particulate loading
 - Single system for multi-pollutant control
 - 90% NO_x removal at temperatures above 500 F (slightly lower at 400 F)
 - 90% SO_x removal at temperatures of 300F to 750F
- Filter removes SO₂, HCl, HF, and other gases utilizing dry sorbent injection of hydrated lime
- Modular design allows for meeting the flow volumes of different applications
- Can retrofit into existing baghouse if equipment is currently in use



ClearSign Duplex Plug & Play Technology

9

- ClearSign's Plug & Play is a replacement burner technology with an integrated ceramic tile
- ClearSign achieves very low NOx emissions without the use of SCR and ammonia
- ClearSign is a possible alternative for similar small and midsized heaters due to cost-effectiveness over SCR installation
 - Presently only available in vertical fire configuration
 - Design fits within existing burner opening
- Due to burner design, no issues of flame impingement or coalescing
- Staff conducted site visit on 2/22/19 at an asphalt refinery in Bakersfield, CA to see a demonstration of a ClearSign Duplex Plug & Play burner in operation
 - Operating since May 2018 with no issues
 - Installed in a 15 MMBtu/hr furnace with a single natural draft burner (natural gas)
 - Fired duty for installed Plug & Play burner is 5.5 – 8.0 MMBtu/hr (will be replaced by a new 15 MMBtu/hr Plug & Play burner)
 - NOx emission <5 ppm @3% O₂ and CO emissions <10 ppm
 - Old burner that was replaced was emitting >30 ppm NOx
 - Heater has permit limit of 6 ppm NOx
 - Heater starts and stops daily, ClearSign burner shows no thermal stress/shock




Umicore Catalysis

10

- Meeting with Umicore (Haldor Topsoe) on 3/13/19
- Corrugated catalyst based on a glass fiber structure
- Dual function catalyst for NO_x, CO, and VOC
- Experienced in refinery applications
 - Unique design allows for lower SO₂ to SO₃ conversion and greater activity/unit volume
 - Lower pressure drop, potentially smaller volume
- More than 1,800 installations (gas turbines, coal , cement, biomass, boilers, etc.)
- 395 refinery/petrochemical installations globally
- For high NO_x reductions, NH₃/NO_x mixing is critical to meet performance targets
 - 92% removal with < 5 ppm slip, ammonia/NO_x mixing critical
 - >92% removal is a challenge




	FCC	Steam Methane Reformer	Crude Heater	Vacuum Heater	Cogen	Aux Boiler	Ethylene Cracker
Plugging from refractory/insulation		X	X	X	X	X	
Plugging from fines	X						X
Chrome poisoning		X					X
Vanadium deposition	X		X	X			
Tube leaks					X	X	
Ammonia salt formation	X				X	X	
Dual Function Possible (Green a Current Reference)	X	X	X	X	X	X	X



DuPont Clean Technologies

11

- Conference call with MECS & DuPont Clean Technologies on 4/2/19
- Experience in optimizing emission performance of sulfur recovery plant and sulfuric acid plant operation
 - Tail end treatment
 - Combustion optimization
- Tail end treatment control options
 - Dynawave® Reverse Jet Scrubber – Quenching, SOx absorption and particulate removal all in one vessel
- NOx abatement can be realized by an ozone generation process
- Combustion optimization (sulfuric acid plant furnace)
 - Sulfuric acid plant furnace optimization – VectorWall™ Ceramic Tile
 - Creates optimized flow pattern to create optimal combustion environment in furnace
 - Works with industry experts like John Zink Hamworthy Combustion and Blasch Precision Ceramics to optimize furnace emission performance
 - Reduces NOx emissions





Ammonia Slip and Particulate Matter

Co-pollutant (NSR/BACT)

13

- Stakeholders expressed concern with retrofit co-pollutant emissions
 - Equipment replacement or retrofit with SCR may result in higher PM emissions due to ammonia slip
 - If PM emission increases more than one pound a day, BACT will be required
 - If replaced with new equipment, subject to NSR/BACT but would provide efficiency gains and co-pollutant reductions
 - Feasible technical options to comply, but could be costly:
 - Pre- or Post-treatment
 - Fuel treatment to remove sulfur
- Staff is aware of the concern and more information will be forthcoming

Ammonia/PM Analysis

14

- Analysis of ammonia slip and PM₁₀ in December 2015 Final Program Environmental Assessment for NOx RECLAIM
 - Projected increase use of ammonia by 39.5 tons per day (tpd) does not mean increased emissions of ammonia by 39.5 tpd
 - 39.5 tpd represents the amount injected by all flue gas streams by all potential SCRs needed to reduce NOx
 - Majority of the ammonia will react with NOx in flue gas with a small amount of unreacted ammonia
 - Regional simulation analyses were conducted to determine impacts of increased ammonia
 - NOx reduced by 14 tpd, resulting in an annual PM_{2.5} decrease of approximately 0.7 µg/m³
 - Increased use of ammonia results in an annual increase of PM_{2.5} by 0.6 µg/m³
 - Increased ammonia from the NOx shave would result in net annual PM_{2.5} decrease of 0.1 µg/m³
 - Overall decrease in annual PM_{2.5} would occur provided that all 14 tpd of NOx emissions are reduced
 - Concluded the impacts to regional PM_{2.5} and ozone due to ammonia slip in simulations would not create a significant impact



Cost Effectiveness

Cost-Effectiveness

16

- Cost-effectiveness is a measure comparing costs of pollution reduction to amount of pollutant reduced
 - Measured in cost per ton of pollutant reduced
- South Coast AQMD typically uses the Discounted Cash Flow Method to calculate cost effectiveness
 - Cost-Effectiveness = Present Value/Emissions Reduced Over Equipment Life
 - Present Value = Capital Cost + (Annual Operating Costs x Present Value Formula)
 - Present Value Formula = $(1 - 1/(1+r)^n)/r$
 - $r = (i-f)/(1+f)$
 - i = nominal interest rate
 - f = inflation rate
 - n = number of cycles
- South Coast AQMD Governing Board established \$50,000/tons of NOx removed with approval of 2016 Air Quality Management Plan

EPA SCR Cost Model

17

- Staff will evaluate cost-effectiveness of installing SCRs based on EPA cost model
- U.S. EPA's Air Pollution Control Cost Estimates Spreadsheet for Selective Catalytic Reduction* used to determine retrofit cost
 - Methodology based on U.S. EPA Clean Air Markets Division Integrated Planning Model
 - Costs of SCR depends on size of unit, emission rate, fuel type burned, NOx removal efficiency, reagent consumption rate, and catalyst costs
 - Capital cost annualized over 25 years at 4% interest rate
 - Inflation accounted for in Chemical Engineering Plant Cost Index (CEPCI)
 - Dec 2018 CEPCI equals 616
 - Values reported in 2018 dollars
 - Conservative cost model number and assumes cost for SCR retrofit
 - Staff using degree of difficulty (retrofit factor) to address challenging installations (e.g., space constraints)
 - Retrofit difficulty level: 0.8 to 1.5
 - Retrofit factor provided in survey by stakeholders
 - Retrofit factor of 1.2 is used if not provided
 - Running SCR model at various concentration levels to determine cost effectiveness

* Available at: http://epa.gov/sites/production/files/2017-12/documents/scrcostmanualchapter7thedition_2016revisions2017.pdf

EPA SCR Cost Model and CEPCI

18

Chemical Engineering Plant Cost Index (CEPCI)

Components of Index	Weight of Components	
Equipment Index:		
Heat exchangers and tanks	34	
Process machinery	13	
Pipe, valves, and fittings	19	
Process instruments	10	
Pumps & compressors	6	
Electrical equipment	7	
Structural supports & miscellaneous	11	% of total
	100	51
Construction Labor Index		29
Buildings Index		5
Engineering and Supervision		15
Total		100

Cost Estimates

19

- EPA SCR cost model only applicable to SCR installations (e.g., not burner retrofits, other control technologies)
- Stakeholders provided cost estimates for currently installed and planned SCR when available
- Technology control suppliers provided additional cost estimates (site specific considerations not included)
- For those units requiring >92% removal efficiency from SCR to achieve BARCT, the cost of burners will be added to the overall cost effectiveness from the EPA SCR cost model
 - Burner costs and operating cost provided in survey from stakeholders
 - Discounted Cash Flow will be used to calculate cost effectiveness for burner control in units that require burner control

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Industrial

Is the SCR for a new boiler or retrofit of an existing boiler?

Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty.
Enter 1 for projects of average retrofit difficulty.

1.2

Retrofit factor provided
by stakeholder in survey
and default of 1.2 used if
not provided

Complete all of the highlighted data fields:

What is the maximum heat input rate (QB)?

28.5 MMBtu/hour

What is the higher heating value (HHV) of the fuel?

1,400 Btu/scf

What is the estimated actual annual fuel consumption?

99,760,143 scf/year

Enter the net plant heat input rate (NPHR)

8.2 MMBtu/MW

Reported input values
from survey

Default value - used to estimate the amount of electricity needed for daily
operation of SCR (e.g. ammonia vaporization, ID fan, etc.)

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates (t_{SCR})

365 days

Based on operating hours reported in survey

Number of days the boiler operates (t_{plant})

365 days

Inlet NO_x Emissions ($NO_{x,in}$) to SCR

0.045 lb/MMBtu

NO_x permit limit (CEMS Data if no permit limit)

NO_x Removal Efficiency (EF) provided by vendor

86.5 percent

Reduction required to achieve proposed BARCT limit

Stoichiometric Ratio Factor (SRF)

1.050

*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Estimated operating life of the catalyst (H_{catal})

24,000 hours

Typical catalyst life 3 to 5 years (3 years used)

Estimated SCR equipment life

25 Years*

* For industrial boilers, the typical equipment life is between 20 and 25 years.

Concentration of reagent as stored (C_{stored})

19 percent

Density of reagent as stored (ρ_{stored})

58 lb/cubic foot

Aqueous ammonia

Number of days reagent is stored ($t_{storage}$)

14 days

To validate the data inputs, staff set reduction to 99.9% to verify NO_x removed is within 2 tons/year of reported annual emissions (actual reported NO_x emissions used and adjusted accordingly)

21

Number of SCR reactor chambers (n_{scr})

1

Number of catalyst layers (R_{layer})

3

Number of empty catalyst layers (R_{empty})

1

Ammonia Slip (Slip) provided by vendor

5 ppm

Volume of the catalyst layers ($Vol_{catalyst}$) (Enter "UNK" if value is not known)

UNK Cubic feet

Flue gas flow rate ($Q_{fluegas}$) (Enter "UNK" if value is not known)

UNK acfm

Gas temperature at the SCR inlet (T)

650 °F

Base case fuel gas volumetric flow rate factor (Q_{fuel})

484 ft³/min-
MMBtu/hour

Default values in SCR cost model - Quote from manufacturer for typical install is 2 chambers (1 empty) with 1 layer of catalyst

Enter the cost data for the proposed SCR:

Desired dollar-year

CEPCI for 2018

Annual Interest Rate (i)

Reagent ($Cost_{reag}$)

Electricity ($Cost_{elect}$)

Catalyst cost ($CC_{replace}$)

Operator Labor Rate

Operator Hours/Day

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

2018		
616	Enter the CEPCI value for 2018	584.6 2012 CEPCI
4	Percent	
3.56	\$ /gallon for a 19 percent solution of ammonia	
0.128	\$ /kWh	
	\$ /cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst	
285.00		
60.00	\$ /hour (including benefits)*	
24.00	hours/day	

CEPCI
December
2018

22

INDUSTRIAL			
Revenue Thousand Dollars	Sales Megawatt/hour	Customers Count	Price Cents/kWh
138,778	773,398	1,402	17.94
1,128,585	19,899,178	8,238	8.04
587,589	10,211,861	34,251	5.58
515,209	7,902,409	8,575	6.52
3,480,735	27,143,427	148,881	12.82
882,415	9,144,825	14,887	7.24
244,392	1,753,431	4,304	13.94

(default: \$0.071)

Confirmed price of reagent grade aqueous ammonia from local supplier (factored freight cost into price)

Adjusted to 24 hours for refinery operations (default: 4 hours)

Quote from several catalyst manufacturers and averaged catalyst cost* (default: \$160)

*Catalyst volume proprietary and based on catalyst technology selection

=(K19+L19)*('Data Inputs'!C52/'Data Inputs'!F52)*0.6+(K19+L19)*('Data Inputs'!C52/'Data Inputs'!F52)*0.4*1.2

E

F

G

H

Cost Estimate

Total Capital Investment (TCI)

TCI for Oil and Natural Gas Boilers

For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:

$$TCI = 80,000 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$$

For Oil and Natural Gas-Fired Utility Boilers >500 MW:

$$TCI = 60,670 \times B_{MW} \times ELEVF \times RF$$

For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :

$$TCI = 7,270 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEVF \times RF$$

For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :

$$TCI = 9,760 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEVF \times RF$$

For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:

$$TCI = 5,275 \times Q_B \times ELEVF \times RF$$

For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:

$$TCI = 7,082 \times Q_B \times ELEVF \times RF$$

Total Capital Investment (TCI) =

\$1,568,994

in 2018 dollars

23

Installation cost varies, but using 40% of Total Capital Investment. Staff proposing to increase installation cost by 20% to account for Senate Bill (SB) 54 labor (construction) rates in CA



Rule Considerations


Considerations for Initial Rule Concept

25

- Difficult installations
 - Firebox floor spacing constraints for burner retrofit
 - Space constraints around specific equipment
 - Establish physical criteria and/or definition that constitutes space constraint or firebox constraint
 - Potential options for new more efficient equipment with similar foot print
- Phased in implementation schedule to allow additional time for difficult installations and turnaround schedule
 - Phase one – X% of equipment, focusing on the oldest units with no control and highest emissions
 - Phase two – Y% of additional equipment
 - Phase three – 100% of equipment, difficult installations and/or equipment replacements
- Low-usage exemptions
 - Capacity threshold
 - Hours operated per year or over multiple years
- Allow keeping higher NOx limits for units close to BARCT limit
- Maintain existing ammonia permit limit, only if:
 - Meeting the NOx BARCT limit and not upgrading equipment

Next Steps

26



Rule 1109.1 Staff Contacts

27

Heather Farr
Program Supervisor
hfarr@aqmd.gov
909.396.3672

Jong Hoon Lee, Ph.D.
AQ Specialist
jhlee@aqmd.gov
909.396.3903

Sarady Ka
AQ Specialist
ska@aqmd.gov
909.396.2331



Michael Krause
Planning & Rules Manager
mkrause@aqmd.gov
909.396.2706

RECLAIM Staff Contacts

28

Kevin Orellana
Program Supervisor
korellana@aqmd.gov
909.396.3792

Gary Quinn, P.E.
Program Supervisor
gquinn@aqmd.gov
909.396.3121

Michael Morris
Planning & Rules Manager
mmorris@aqmd.gov
909.396.3282

